



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

VELLAYAMBALAM, THIRUVANANTHAPURAM
Telephone No - 0471-2735303, E-mail - aeeqcsdtvm@gmail.com

Test Report

Test Report. No -KWA/QCDL/TVM/2021/2084

Customer Name & Address			1. Date of Receipt : 18.10.2021	
A. J Central Senior Secondary School, Kazhakkuttam			2. Sampling done by :The Customer	
			3. Sample Code : 2021/2084	
			4. Source of Sample : Tube Well	
			5. Sample Quantity : 200ml	
			6. Test Performing Dates	
			From : 18.10.2021 To :19.10.2021	
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	PRESENT
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

Jaya

* End of Report *

KWA/QCDL/TVM/R-41/2021	Issue No:1	Issue Date 10.02.2021
Rev.No: 00	Rev Date: 00	Page 1 of 1

